

**SGS Statutory Services Belgium ASBL/VZW**

Organsisme Notifié / Aangemelde Instantie / Notified Body Nr. 1179

**Contact zetel :**

Noorderlaan 87  
 B- 2030 Antwerpen  
 t. (0) 3 545 48 88  
 f. (0) 3 545 48 89  
 e. [sgs.antwerp.sgsssb@sgs.com](mailto:sgs.antwerp.sgsssb@sgs.com)

<b>VERKLARING VAN TOEZICHT OP EINDCONTROLE IN                  OVEREENSTEMMING MET DRUKAPPARATUUR                  RICHTLIJN 2014/68/EU                  DECLARATION OF MONITORING OF FINAL                  ASSESSEMENT IN CONFORMITY TO PRESSURE                  EQUIPEMENT DIRECTIVE 2014/68/EU</b>		CERTIFICAAT N° <b>A20181910-C018540-GSc-03</b> CERTIFICATE Nr : DATUM : <b>24-10-2018</b> DATE :	
Fabrikant of zijn afgevaardigde in de Europese Gemeenschap: <b>Heesmans Installatie Techniek B.V., Brandvoortse Dreef 101, 5706 SL HELMOND</b>			
Naam / Name : Adres / Address :		Heesmans Installatie Techniek B.V. Brandvoortse Dreef 101, 5706 SL Helmond	
Overeenstemmingsbeoordelingsprocedure : Conformity assessment procedure :		A2 (toezicht op de eindcontrole) A2 (monitoring of final assessment)	
<b>Beschrijving van de drukapparatuur / Description of the pressure equipment:</b>			
Serie Nr Model / type Samenstellingstekening Risico Categorie Groep van de stoffen Beoogd gebruik Volume Nominale diameter Ontwerpdruk Min. ontwerptemperatuur Max. ontwerptemperatuur Corrosie/erosietoeslag Constructie jaar Andere : ..... Beproeving : Testdruk Test Datum Veiligheidsappendages : Debiet overdrukventiel Openingsdruk overdrukventiel	Serial N° Model / type Assembly drawing Risk Category Group of medium Intended use Volume Nominal diameter Design pressure Min. design temperature Max. design temperature Corrosion/erosion allowance Year of construction Others : ..... Testing : Test pressure Test Date Safety Equipment : Capacity safety valve Opening pressure safety valve	FGO 043/5741SX36/A Airconditioning installatie Tek.tab 2 dossier Formula Air II 2 Airconditioning installatie 9,45 kg R-410A (gasgroep 2) 6 mm / 28 mm 40 -20 100 0,00005 2018 ..... 44 19-10-2018 Indirecte beveiliging (HP/LP) Pressostaat 39 bar	Liters mm Barg °C °C mm Bar(g) kg/h Barg
Nota:			



This document is issued by the firm SGS under its General Conditions of Service accessible at <http://www.sgs.com/sgs/terms-and-conditions.aspx>. Attention is drawn to the limitation of liability, indemnification and jurisdiction issues defined therein.  
 Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SGS SSB ASBL/VZW  
 Siège/Zetel

Bd International/Internationalelaan, 55/D 1070 Bruxelles/Brussel t+32(0)2 411 60 35 f+32(0)2 411 38 70



Member of the SGS Group



**SGS Statutory Services Belgium ASBL/VZW**

Organsisme Notifié / Aangemelde Instantie / Notified Body Nr. 1179

Wij verklaren dat de hier boven beschreven drukapparatuur conform is aan de van toepassing zijnde eisen volgens directieue 2014/68/EU / We declare that the pressure equipment mentioned above is satisfying the applicable requirements of directive 2014/68/EU.

<p>Project Manager Rachid MOUSSAOUI </p>	<p>Technical Director, </p>
---	---

